

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Great Lakes Vinyl Flooring

655 Woodlyn Road, Johnson City, TN, United States

For the following product(s):

Vinyl Tile:

4.5mm x 7-in x 48-in Vinyl Tile Flooring, 6.0mm x 7-in x 48-in Vinyl Tile Flooring, 6.0mm x 12-in x 24-in Vinyl Tile Flooring (*Maximum thickness: 6.0mm*)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-07998

Valid from: June 15, 2022 to April 30, 2023

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board
ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA