

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Great Lakes Wood Floors

655 Woodlyn Road, Johnson City, TN, United States

For the following product(s):

Engineered Hardwood:

3/8" Engineered Finished Sawn Faced Hardwood, .38" WW-WB Engineered Hardwood, .38" Engineered Filled Hardwood, .38" Engineered Sculpted Hardwood, .38" WW-WB Locking Engineered Hardwood, .44" Engineered WB, .50" Engineered Filled Hardwood, .50" WW-WB Engineered Hardwood

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03853

Valid from: March 1, 2023 to February 29, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA